


ITEM	QTY	DESCRIPTION
①	1 EA	___" EPOXY COATED TAPPING SADDLE (___" O.D. x ___" FLG) OR ___" FABRICATED TAPPING SADDLE (___" O.D. x ___" FLG) OR ___" FABRICATED WELD NOZZLE (___" O.D. x ___" FLG) ___" STAINLESS STEEL TAPPING SADDLE
②	1 EA	___" FLG X MJ GATE VALVE PER SBMWD STD. DWG. W3.1
③	1 EA	___" END CAP WITH 2" FLUSH PORT (FLUSH PORT PER SBMWD STD. DWG. W6.7) (RESTRAINED)
④	1 EA	___" MJ SLEEVE (RESTRAINED W/ "MEGALUG" RESTRAINT)
⑤	___LF	___" CLASS 350 DUCTILE IRON PIPE (RESTRAINED W/ "MEGALUG" RESTRAINT OR APPROVED EQUAL)
⑥	1 EA	___" PIPELINE SEAL AND INSULATOR, INC INSULATING KIT TO BE USED BETWEEN THE TAPPING SADDLE AND VALVE WHEN DISSIMILAR METALS (DUCTILE IRON AND STEEL) ARE INVOLVED

REVISION DATE: 1/3/2011

D.D.M.	JAN. 11	SAN BERNARDINO MUNICIPAL WATER DEPARTMENT	DRAWING NUMBER
C.L.R.	APRIL 08		SBMWD
C.L.R.	SEPT. 07	<b>TAPPING DETAIL FOR 4" AND LARGER DEVELOPER-INSTALLED MAINS</b>	W3.5
M.H.L.	JULY 07		
REVISION	DATE		
SCALE: NONE	APPROVED	 MATTHEW H. LITCHFIELD, P.E. RCE 58079	DATE 10/11/11