



| ITEM | QUANTITY | DESCRIPTION |
|------|----------|--|
| ① | | AS REQ'D EXIST. PIPE SIZE X REQUIRED LENGTH CLASS 50 DIP P.E. SPOOL |
| ② | 1 EA | EXIST. PIPE SIZE EBBA IRON MEGALUG OR APPROVED EQUAL |
| ③ | 3 EA | PROPOSED PIPE MAIN SIZE EBBA IRON MEGALUG OR APPROVED EQUAL |
| ④ | | AS REQ'D PROPOSED PIPE MAIN SIZE X REQUIRED LENGTH CLASS 50 DIP P.E. SPOOL |
| ⑤ | 3 EA | EXIST. PIPE SIZE EBBA IRON MEGALUG OR APPROVED EQUAL |
| ⑥ | 1 EA | PROPOSED PIPE MAIN SIZE M.J. END CAP WITH 2" TAP |
| ⑦ | 1 EA | PROP. PIPE MAIN RUN SIZE X EXIST. PIPE SIZE SIDE OUTLET (M.J. X M.J. X FLG UNLESS OTHERWISE SHOWN ON PLAN) |
| ⑧ | 1 EA | EXIST. PIPE SIZE FLG X M.J. GATE VALVE PER SBMWD STD. DWG. W3.1 |
| ⑨ | 1 EA | EXIST. PIPE SIZE X 90° M.J. BEND |
| ⑩ | 1 EA | 2" CHLORINATION AND FLUSHING PORT W/O SERVICE SADDLE PER SBMWD STD. DWG. W6.7 |
| ⑪ | 1 EA | IN-LINE THRUST BLOCK PER SBMWD STD. DWG. W6.11 |

NOTE: ALL MATERIAL, CONSTRUCTION METHODS AND TESTING SHALL BE IN ACCORDANCE WITH SBMWD STANDARDS AND SPECIFICATIONS. A SBMWD INSPECTOR SHALL BE PRESENT AT ALL TIMES DURING CONSTRUCTION UNLESS OTHERWISE APPROVED BY SBMWD.

REVISION DATE: 3/22/2011

SAN BERNARDINO MUNICIPAL WATER DEPARTMENT

DRAWING NUMBER

DETAIL FOR 4'-16' C.I.P. OR D.I.P., CUT AND PLUG EXISTING WATER MAIN

SBMWD

D.D.M. MAR. 11

REVISION DATE

W6.25

APPROVED

Matthew H. Litchfield
MATTHEW H. LITCHFIELD, P.E. RCE 58079

DATE

10/11/11

SCALE: NONE